

## 15.4.12. H33 (Unspecified Voltage between Indoor and Outdoor)

### Malfunction Decision Conditions

The supply power is detected for its requirement by the indoor/outdoor transmission.

### Malfunction Caused

- Wrong models interconnected.
- Wrong indoor unit and outdoor unit PCBs used.
- Indoor unit or outdoor unit PCB defective.

### Troubleshooting

